

CITY OF SPRINGFIELD  
INTER-OFFICE MEMORANDUM

ATTENTION OF Memo to file

DATE August 12, 1977


DEPARTMENT \_\_\_\_\_

Re: Woodland Hills  
pressure line break

This office was notified of the above break on 8-11-77 at approximately 9:15 a.m., by Omer Boyce. Bob Corson and I loaded the barrel of HTH and responded to the call. We found the break in the 1800 block of Valley Water Mill Road. The raw sewage had run down the ditch for approximately 100 yards to the west. No estimate was made of the volume lost. We chlorinated the sewage and notified pump station personnel to turn off the pumps at Goff Rancho and Woodland Hills. City crews repaired the broken line and service was restored at about 10:30 p.m.

*1800 E. Valley Water Mill*

SIGNED

  
John T. Witherspoon, S & E